

# Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

<b>Manufacturer</b>	<b>Bachofen AG</b>
<b>Address</b>	Ackerstrasse 45, Uster, 8610, Switzerland
<b>Type</b>	Switches - Level
<b>Description</b>	Trimod Besta float operated liquid level switches and mounting accessories.  Types A, B, DA, DB, UA, UB, HA, HB, TDA, TDB, Z, X and P and combinations thereof, including flange modules to ANSI, DIN, BS, JIS and Besta standard and float modules.
<b>Trade Name</b>	A, B, DA, DB, UA, UB, HA, HB, TDA, TDB, Z, X and P
<b>Application</b>	Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2 and ENV3 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1 – 2002.
<b>Specified Standard</b>	Manufacturer's specification
<b>Ratings</b>	Operating temperature ratings: A, B: 0 to 330°C XA, XB: -30 to 330°C DA, DB: -30 to 120°C UA, UB, XUA, XUB: -30 to 80°C HA, HB: 0 to 400°C TDA, TDB: -196 to 270°C

---

**Thorsten Wolff**

Senior Specialist to Lloyd's Register EMEA  
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

## Type Approval Certificate

Z: -30 to 145°C  
P: 0 to 250°C  
5P: 0 to 400°C

**Electrical ratings:**

A: 250 VAC 5 A  
30 VDC 5 A  
B: 3 VDC 300 mA  
B (Ex-i application): max.30 VDC, max. 300 mA, max. 0.12 VA  
 $Li \approx 0 \mu\text{H}$ ,  $Ci \approx 0 \text{ nF}$   
Z (Ex-d application): 250 VAC 5 A  
250 VDC 0.25 A  
XA (Ex-d application): 250 VAC 5 A  
250 VDC 0.25 A  
XB (Ex-i application): max.30 VDC, max. 300 mA, max. 0.12 VA  
 $Li \approx 0 \mu\text{H}$ ,  $Ci \approx 0 \text{ nF}$

**Additional Tests**

Types A, B, HA and HB:	IP65
Types DA, DB, TDA, TDB:	IP66 / IP 67
Types UA, UB:	IP 68

**Other Conditions**

Z and X types have an ingress protection rating of IP 66 / IP 67 in general.  
Types Z, B and X are suitable for use in hazardous areas. Ratings for application in hazardous areas are to be obtained from applicable Ex Certificates.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. HTS/ETS 40537-20/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.